

Honeywell 2000 And 2300 Controllers

Equipment:	Honeywell 2000 And 2300 Controllers	Date Issued:	3-6-03
		Revised:	no
Additional Reference:	Honeywell 2000 or 2300 manual	Revision #:	0
By:	Ted Glassmire, Service Support Coordinator		Astec Service Department

HONEYWELL 2000 AND 2300 CONTROLLERS

GROUP	FUNCTION	2000	VALUE	2300
TIMER	DISABLE			
TUNING	CYCLE TIME	20		20
	OUT ALG	NONE		NONE
	SECURITY	0		0
	LOCK	NONE		NONE
	AUTOMA			ENABLE
	RNHOLD			DIS
	SP SEL			DIS
A TUNE	FUZZY			DIS
	TUNE			DIS
ALGOR	CTRL ALG	ON/OFF		ON/OFF
	OUT ALG	RELAY		RELAY
INPUT 1	DECIMAL	8888		8888
	UNITS	F		F
	INPUT 1TYPE	JTCL		JTCL
	XMITER1			LIN
	IN 1 HI	770		900
	IN 1 LO	0		20
	RATIO1			1
	BIAS 1	0		0
	FILTER	0		0
	BRNOUT	UP		UP
	FREQ	60		60
	DISPLY	PRN		PRN
	LANG	ENG		ENG
CONTROL	SP TRK			NONE
	PWR UP			MAN
	SP HI	770		450-900
	SP LOW	0		20
	ACTION	DIR		DIR
	HYST	0.5		0.5
	FAILSF	0		0